



## Water Quality Monthly Results

**DATE:** October 2016  
**RE:** Corinella Locality (incorporating Corinella, Coronet Bay and Tenby Point)

Parameter	Units	Number of Samples	Monthly Result	Quality standard
<i>Escherichia coli</i>	orgs/100mL	4	0	0
Turbidity	NTU	4	0.1	<5
Trihalomethanes	mg/L	1	0.097	<0.25

For further information regarding the quality standards for parameters please go to Westernport Water's Water Quality webpage

Regards,

Jake Weir  
**WATER QUALITY OFFICER**