



Water Quality Monthly Results

DATE: July 2016
RE: Bass Locality (incorporating Bass and Woolamai)

| Parameter | Units | Number of Samples | Monthly Result | Quality standard |
|-------------------------|------------|-------------------|----------------|------------------|
| <i>Escherichia coli</i> | orgs/100mL | 4 | 0 | 0 |
| Turbidity | NTU | 4 | 0.1 | <5 |
| Trihalomethanes | mg/L | 1 | 0.076 | <0.25 |

For further information regarding the quality standards for parameters please go to Westernport Water's Water Quality webpage

Regards,

Jake Weir
WATER QUALITY OFFICER