

Annual Drinking Water Quality Report 2017-18



Document Status

| | |
|------------------|---|
| Name | Westernport Water Annual Drinking Water Quality Report 2017-18 |
| File location | TRIM: INT18-07571 |
| Document version | Final |
| Date of issue | 29/10/2018 |
| Approved by | General Manager Assets & Operations |

Document History

| Issue | Revision | Prepared by | Reviewed by | Date |
|------------------------------------|----------|--|--|------------|
| First draft for internal review | 1 | Water Quality & Sustainability Officer | Manager Environment & Product Performance, Treatment Plant Coordinator & General Manager Assets & Operations | 19/09/2018 |
| First draft with Department review | 2 | Water Quality & Sustainability Officer | DHHS Water Sector Liaison Officer | 8/10/2018 |
| Final | 3 | Water Quality & Sustainability Officer | General Manager Assets & Operations | 29/10/2018 |

Authorisation

I authorise the use of this report in the Department of Health and Human Services Annual Report and made freely available on Westernport Water's website – www.westernportwater.com.au

Paul Donohue
General Manager Assets & Operations



WESTERNPORT
WATER.



Table of Contents

| | |
|---|----|
| Document Status | A |
| Document History | A |
| Authorisation | A |
| 1. Introduction | 3 |
| 1.1 Westernport Water - Overview | 3 |
| 1.2 Aims and Objectives of this Report | 3 |
| 1.3 Westernport Water's Commitment to Drinking Water Quality | 3 |
| 1.4 2017-18 performance | 3 |
| 2. Characterisation of Westernport Water's Supply System | 5 |
| 2.1 System Overview | 5 |
| 2.2 Water Sources | 5 |
| 2.2.1 Bass River | 5 |
| 2.2.2 Groundwater | 5 |
| 2.3 Source water protection | 5 |
| 3. Water treatment and quality management systems | 8 |
| 3.1 Water treatment | 8 |
| 3.1.1 Oxidation | 8 |
| 3.1.2 Adsorption | 8 |
| 3.1.3 Coagulation/flocculation | 8 |
| 3.1.4 Dissolved air floatation and filtration (DAFF) | 8 |
| 3.1.5 Fluoridation | 8 |
| 3.1.6 pH correction | 9 |
| 3.1.7 Disinfection | 9 |
| (a) Ultraviolet (UV) | 9 |
| (b) Chlorine | 9 |
| (c) Chloramination | 9 |
| 3.2 Major changes to the arrangements for water supply | 11 |
| 3.3 Issues | 12 |
| 4. Emergency, incident and event management | 13 |
| 5. Quality of drinking water for the period of 1 July 2017 to 30 June 2018 | 14 |
| 5.1 <i>E.coli</i> | 15 |
| 5.2 Trihalomethanes (THM's) | 17 |
| 5.3 Turbidity | 19 |
| 5.4 Other algae, pathogen, chemical or substance not specified above that may pose a risk to human health | 21 |
| 5.4.1 Fluoride | 21 |



| | | |
|-------|---|----|
| 5.4.2 | Copper..... | 23 |
| 5.4.3 | Lead | 25 |
| 5.4.4 | Zinc..... | 27 |
| 5.4.5 | Manganese..... | 29 |
| 5.4.6 | All other chemicals or monitored parameters | 31 |
| 5.4.7 | Raw water monitoring | 32 |
| 5.4.8 | Analysis of results..... | 33 |
| 5.4.9 | Water quality improvements in 2017-18..... | 33 |
| 5.5 | Aesthetics | 34 |
| 5.5.1 | Aluminium (acid-soluble)..... | 34 |
| 5.5.2 | True colour | 36 |
| 5.5.3 | Iron | 38 |
| 5.5.4 | pH..... | 39 |
| 6. | Complaints relating to water quality..... | 40 |
| 6.1 | Summary of complaints | 40 |
| 6.2 | Response to complaints..... | 41 |
| 7. | Findings of the most recent risk management plan audit..... | 43 |
| 8. | Undertakings under section 30 of the Act..... | 44 |
| 9. | Exemption under section 20 of the Act..... | 44 |
| 10. | Glossary of Terms..... | 46 |



1. Introduction

1.1 Westernport Water - Overview

Westernport Region Water Corporation (WPW) provides water and wastewater services in an economically, environmentally and socially sound manner to customers within its service area.

WPW services Phillip Island and an area of the mainland from The Gurdies to Archies Creek. Individual towns that are provided with drinking water include Bass, Grantville, Corinella, Kilcunda (including Dalyston), San Remo, Cape Woolamai, Rhyll, Cowes and Ventnor. A map of the service area is included in this report as figure 1-1

1.2 Aims and Objectives of this Report

Under section 26 of the *Safe Drinking Water Act 2003* (SDWA), WPW is required to provide the Department of Health and Human Services (DHHS) with an annual report on the quality of drinking water supplied to its customers.

The aim of this report is to provide all stakeholders, including the community, with water quality information compliant with Section 26 of the SDWA. The report covers the period of 1 July 2017 to June 30 2018 and covers issues relating to the quality and management of drinking water.

1.3 Westernport Water's Commitment to Drinking Water Quality

WPW is committed to a comprehensive risk management approach to the safe provision of drinking water to its customers. This is achieved through the adoption of the framework for the management of drinking water quality outlined in the Australian Drinking Water Guidelines 2011, (ADWG) and implemented through continual review and improvement of WPW's Water Quality Risk Management Plan (WQRMP).

WPW's commitment to drinking water quality is highlighted in the foundation of its drinking water quality policy (endorsed by executive management and board). The policy demonstrates WPW's support and long-term commitment to the development and implementation of an effective system for drinking water quality management.

1.4 2017-18 performance

WPW met all its obligations to provide water compliant with the *Safe Drinking Water Act 2003* and *Safe Drinking Water Regulation 2015* throughout 2017-18.

Performance against drinking water quality standards outlined in the *Safe Drinking Water Regulations 2015* (SDWR) are presented in section 5.




Figure 1-1-1 WPW region including water sampling localities

2. Characterisation of Westernport Water's Supply System

2.1 System Overview

WPW has a single water supply storage (Candowie Reservoir), which is an on-stream storage on Tennent Creek, located in the Bass Hills near Glen Forbes.

Water is treated at the Ian Bartlett Water Purification Plant (IBWPP) and then reticulated to communities through a single main supply line, with a number of smaller off takes servicing each of the residential communities within WPW's area of supply. A plan of the distribution system is included in this report as figure 2-1.

Raw water quality in Candowie Reservoir is generally considered poor for human consumption due to intensive farming activities and runoff from cleared land within the catchment area. Before treatment, the raw water is high in nutrients and organics and quality is typical of water that is sourced from an unprotected catchment. Following treatment, the water complies with the ADWG and standards outlined in regulation 12 of SDWR.

Localities and population supplied in WPW region, water sources and the treatment process are outlined in table 3-1 under section 3.

2.2 Water Sources

Other sources of water are available to supplement Candowie Reservoir during low rainfall periods. These alternative sources are surface water from the Bass River and groundwater from bores constructed in the Corinella Groundwater Management Unit (GMU). Water from these alternative sources is pumped via a pipeline to Candowie Reservoir for centralised storage and treatment at the IBWPP. Table 3-1 lists where raw water is sourced and the treatment processes used to produce potable water to customers

2.2.1 Bass River

Westernport Water's pump station, located along the banks of the Bass River, is used to transfer water into Candowie Reservoir. This is licenced under the Bass River Bulk Entitlement. 272 Mega Litres (ML) of water was extracted from the river during the 2017-18 reporting period.

2.2.2 Groundwater

WPW have four bores licenced to take and use groundwater within the Corinella GMU. WPW has an entitlement of 490 ML/year. No groundwater was extracted during 2017-18 reporting period.

2.3 Source water protection

Section 1.3 details WPW's commitment to drinking water quality. Aligned with the framework for the management of drinking water quality is the catchment to tap approach. To demonstrate this approach for the catchment, WPW builds our understanding of the source water risks by:

- I. Undertake sanitary survey's of the catchment. A survey was undertaken in 2014.
- II. A comprehensive raw water monitoring program for pathogens, blue green algae, organic chemicals and radiological parameters



- III. Continuous performance monitoring at the treatment plant.
- IV. Ongoing contractual partnership with Bass Coast Landcare and Melbourne Water on improving catchment health.

3. Water treatment and quality management systems

WPW operates a comprehensive water quality management system that complies with the *SDWA 2003* and *SDWR 2015*. The system is designed to ensure that customers receive drinking water that is safe and of good quality.

3.1 Water treatment

Raw water from Candowie Reservoir is treated using a combination of oxidation, adsorption, flocculation, coagulation, dissolved air flotation, filtration, pH correction, fluoridation and disinfection at the IBWPP. The source water is predominantly high in nutrients and organics, and quality is typical of water that is sourced from an open, unprotected catchment. The following sections and table 3-1 highlight the treatment process used at IBWPP.

3.1.1 Oxidation

Oxidation is used to remove iron and manganese from the water. Potassium permanganate is added to aid the removal process.

3.1.2 Adsorption

Adsorption is a process where a solid is used to remove a soluble substance from the water. WPW uses Powdered Activated Carbon (PAC) as the solid in water. Water is pumped through PAC and accumulates the soluble substances in the filter. The PAC is then removed from the process, subsequently removing the substance from the water. Adsorption is used to control potential taste and odour issues, and to remove algal toxins from the water.

3.1.3 Coagulation/flocculation

Coagulation is the process to remove fine suspended particles to aid the removal of colour and turbidity. Particles have a negative charge, repelling each other and allowing them to remain suspended in water as they will not clump together and settle out. Coagulation involves the addition of a coagulant (aluminium sulphate) with a positive charge that neutralises the negative charge enabling the fine particles to merge to create larger particles. Flocculation involves gentle mixing of the water which causes the particles to collide increasing their size to visible suspended solids. The visible particles are called a 'floc'.

3.1.4 Dissolved air floatation and filtration (DAFF)

DAFF is a process of injecting air particles into water causing the floc to float to the surface. The floc is then removed to waste and the clear water is filtered through graded filter media. The purpose of DAFF is to produce water low in turbidity.

Over time filters become blocked with particles from the floc. To overcome the blockage, the filters are backwashed periodically to allow optimum production in the filters to produce consistently low turbidity results.

3.1.5 Fluoridation

Fluoride is added to treated water at a level that helps protect teeth against decay. Fluoride does not alter the taste or smell of water. Fluoridated water is delivered to all localities in WPW distribution system.



3.1.6 pH correction

To ensure treated water is within the ADWG desired range, caustic soda is added to raise pH.

3.1.7 Disinfection

(a) Ultraviolet (UV)

UV light inactivates microorganisms by damaging their nucleic acid, thereby preventing them from replicating and disrupting their ability to infect hosts. UV disinfection can be used for the inactivation of chlorine resistant pathogens (e.g. Cryptosporidium and Giardia).

(b) Chlorine

The final stage of treatment at IBWPP is chlorine disinfection. Disinfection is required to prevent the spread of waterborne pathogens and to retain an appropriate chlorine residual throughout the system.

(c) Chloramination

WPW adopt the method of chloramination to address taste & odour issues and total chlorine residuals to the extremities of the distribution system. Chloramination is the process of adding chlorine to a small amount of ammonia. All localities (except Bass) receive chloraminated water.

Table 3-1 Source water and treatment processes

| Water Sampling Locality | Population supplied ¹ | Source water ² | Storage | Treatment plant | Treatment Process | | | | | | | | | | | | | | |
|--|----------------------------------|--|--------------------|-----------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|---|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| | | | | | Clarification | | Filtration | Disinfection | | | Other | | Added substance(s) | | | | | | |
| | | | | | Coagulation and flocculation | Dissolved air flotation | Granular Media Filter | Chlorine gas | Sodium hypochlorite | Ultraviolet (UV) ⁴ | Activated carbon (PAC) | Sludge-handling (mechanical with chemical addition) | Caustic soda | Aluminium-based coagulants | Potassium permanganate | Chlorine | Ammonia ³ | Fluoride | |
| Bass (including Woolamai) | 600 | Bass River, Tennent Creek, and Corinella Bores | Candowie Reservoir | IBWPP | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | | |
| Cape Woolamai (incorporating Smiths Beach, Sunderland Bay, Sunset Strip and Wimbleton Heights) | 3200 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Corinella (incorporating Coronet Bay) | 1710 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Cowes (incorporating Silverleaves) | 4050 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Grantville (incorporating Pioneer Bay) | 1070 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Kilcunda (incorporating Dalyston and Archies Creek) | 930 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Rhyll | 670 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| San Remo (incorporating Newhaven) | 1470 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| Ventnor | 830 | | | | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |

■ Treatment/Substance was applied regularly in 2017-18

□ Treatment/Substance was applied intermittently in 2017-18

¹ Population sourced from 2016 census data

² Water sources listed are used to augment supply to Candowie and subsequently supply all localities

³ Ammonia as aqua ammonia used with sodium hypochlorite for chloramination disinfection.

⁴ UV disinfection was added to IBWPP in March 2018. A UV unit constructed in 2001 is also used for water supplied to The Penguin Parade and Nobbies area.

3.2 Major changes to the arrangements for water supply

On 30 May 2018 a government gazette No. S 252 Wednesday 30 May 2018 was published that included changes to WPW's water sampling locality. The changes are as follows:

- The water sampling localities named Cape Woolamai, Rhyll, San Remo and Ventnor were merged and substituted as the water sampling locality named San Remo–Phillip Island.
- The water sampling localities named Corinella and Grantville, were merged and substituted to form the water sampling locality named Water Line.

The changes to WPW's sampling localities are displayed in figure 3-1.

Due to the locality change, data in section 5 will be presented in two tables; one which displays data from 1 July 2017 to 29 May 2018 the second will be from 30 May 2018 to 30 June 2018.




Figure 3-1 Westernport Water's updated sampling localities.

3.3 Issues

There were no issues during the 2017-18 reporting period that affected treatment processes which may of lead to potential or actual exceedances of drinking water quality standards.



4. **Emergency, incident and event management**

No Section 22 notifications or treatment issues occurred during 2017-18.



5. Quality of drinking water for the period of 1 July 2017 to 30 June 2018

All parameters sampled by WPW throughout 2017-18 were compliant with Regulation 12 and 13 of the SDWR 2015 and health related guideline values in the ADWG. The following tables depict the performance for 1 July, 2017 to 30 June, 2018.

5.1 *E.coli*

The SDWR 2015 stipulates that all samples of drinking water collected are found to contain no *E. coli* per 100mL of drinking water, with the exception of any false positive sample. Sample frequency in relation to *E.coli* is weekly in each defined locality. The water quality with respect to *E. coli* was compliant with this standard as per table 5.1-1 and 5.1-2 below:

Table 5.1-1 *E.coli* 1 July 2017- 29 May 2018

| Locality | Frequency | Number of Samples | Maximum detected (orgs/100mL) | Number of detections and investigations conducted (s. 22) | Number of samples where standard was not met (s 18) |
|---------------|-----------|-------------------|-------------------------------|---|---|
| Bass | Weekly | 100 | 0 | 0 | 0 |
| Cape Woolamai | Weekly | 92 | 0 | 0 | 0 |
| Corinella | Weekly | 95 | 0 | 0 | 0 |
| Cowes | Weekly | 97 | 0 | 0 | 0 |
| Grantville | Weekly | 240 ¹ | 0 | 0 | 0 |
| Kilcunda | Weekly | 97 | 0 | 0 | 0 |
| Rhyll | Weekly | 96 | 0 | 0 | 0 |
| San Remo | Weekly | 144 ² | 0 | 0 | 0 |
| Ventnor | Weekly | 96 | 0 | 0 | 0 |

¹locality includes sampling from two treated storage tanks that supply Grantville and Corinella.

²locality includes sampling from a treated storage basin that supplies the localities of San Remo, Cape Woolamai, Cowes, Rhyll and Ventnor.

Table 5.1-2 *E.coli* 30 May - 30 June 2018

| Locality | Frequency | Number of Samples | Maximum detected (orgs/100mL) | Number of detections and investigations conducted (s. 22) | Number of samples where standard was not met (s 18) |
|-------------------------|-----------|-------------------|-------------------------------|---|---|
| Bass | Weekly | 8 | 0 | 0 | 0 |
| Cowes | Weekly | 10 | 0 | 0 | 0 |
| Kilcunda | Weekly | 8 | 0 | 0 | 0 |
| San Remo-Phillip Island | Weekly | 38 ¹ | 0 | 0 | 0 |
| Water Line | Weekly | 28 ² | 0 | 0 | 0 |

¹locality includes sampling from a treated storage basin that supplies the localities of San Remo, Cape Woolamai, Cowes, Rhyll and Ventnor.

²locality includes sampling from two treated storage tanks that supply Grantville and Corinella.

5.2 Trihalomethanes (THM's)

The SDWR 2015 stipulates that all samples of drinking water collected are less than or equal to 0.25 milligrams per litre of drinking water. Sample frequency in relation to THM's is monthly in each defined locality. The water quality with respect to THM's was compliant with this standard as per table 5.2-1 and 5.2-2 below:

Table 5.2-1 THM's 1 July 2017- 29 May 2018

| Locality | Frequency | Number of Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | No of samples where standard was not met (s. 18) |
|---------------|-----------|-------------------|--|----------------|----------------|--|
| Bass | Monthly | 11 | 0.25 | 0.14 | 0.11 | 0 |
| Cape Woolamai | Monthly | 11 | | 0.16 | 0.13 | 0 |
| Corinella | Monthly | 11 | | 0.12 | 0.09 | 0 |
| Cowes | Monthly | 11 | | 0.16 | 0.13 | 0 |
| Grantville | Monthly | 11 | | 0.10 | 0.08 | 0 |
| Kilcunda | Monthly | 12 | | 0.13 | 0.10 | 0 |
| Rhyll | Monthly | 11 | | 0.16 | 0.13 | 0 |
| San Remo | Monthly | 11 | | 0.16 | 0.13 | 0 |
| Ventnor | Monthly | 11 | | 0.14 | 0.10 | 0 |

Table 5.2-2 THM's 30 May - 30 June 2018

| Locality | Frequency | Number of Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | No of samples where standard was not met (s. 18) |
|-------------------------|-----------|-------------------|--|----------------|----------------|--|
| Bass | Monthly | 1 | 0.25 | 0.10 | 0.10 | 0 |
| Cowes | Monthly | 1 | | 0.11 | 0.11 | 0 |
| Kilcunda | Monthly | 1 | | 0.12 | 0.12 | 0 |
| San Remo-Phillip Island | Monthly | 4 | | 0.14 | 0.14 | 0 |
| Water Line | Monthly | 2 | | 0.09 | 0.09 | 0 |

5.3 Turbidity

The SDWR stipulate that the 95th percentile of drinking water samples collected in any 12 months period must be ≤ 5.0 NTU. All localities were compliant with the water quality standard as per table 5.3-1 and 5.3-2 below:

Table 5.3-1 Turbidity 1 July 2017- 29 May 2018

| Locality | Frequency | Number of Samples | Maximum turbidity in a sample (NTU) | Maximum 95 th percentile of turbidity results in any 12 months (NTU) | Number of 95 th percentile of results in any 12 months above standard (s 18) |
|---------------|-----------|-------------------|-------------------------------------|---|---|
| Bass | Weekly | 48 | 0.4 | 0.2 | 0 |
| Cape Woolamai | Weekly | 48 | 0.2 | 0.2 | 0 |
| Corinella | Weekly | 48 | 0.7 | 0.4 | 0 |
| Cowes | Weekly | 48 | 1.6 | 0.2 | 0 |
| Grantville | Weekly | 48 | 0.4 | 0.2 | 0 |
| Kilcunda | Weekly | 49 | 0.3 | 0.2 | 0 |
| Rhyll | Weekly | 48 | 0.3 | 0.2 | 0 |
| San Remo | Weekly | 48 | 0.4 | 0.3 | 0 |
| Ventnor | Weekly | 48 | 0.6 | 0.3 | 0 |

Table 5.3-2 Turbidity 30 May - 30 June 2018

| Locality | Frequency | Number of Samples | Maximum turbidity in a sample (NTU) | Maximum 95 th percentile of turbidity results in any 12 months (NTU) | Number of 95 th percentile of results in any 12 months above standard (s 18) |
|-------------------------|-----------|-------------------|-------------------------------------|---|---|
| Bass | Weekly | 4 | 0.1 | 0.2 | 0 |
| Cowes | Weekly | 4 | <0.1 | 0.2 | 0 |
| Kilcunda | Weekly | 4 | 0.1 | 0.2 | 0 |
| San Remo-Phillip Island | Weekly | 16 | 0.2 | 0.2 | 0 |
| Water Line | Weekly | 8 | 0.3 | 0.3 | 0 |

5.4 Other algae, pathogen, chemical or substance not specified above that may pose a risk to human health

WPW regularly tests for other substances in the drinking water they supply to customers. The following sections detail the results for the 2017/18 reporting period

5.4.1 Fluoride

The health-based guideline value for fluoride in the ADWG is 1.5mg/L. In conjunction with this value the *Health (Fluoridation) Act 1973* states that the annual average for fluoride in drinking water must not exceed 1 mg/L. Fluoride concentrations at all locations were compliant during the reporting period as presented in table 5.4.1-1 and 5.4.1-2 below:

Table 5.4.1-1 Fluoride 1 July 2017- 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Target optimum operating fluoride concentration (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|---------------|-----------|---------|--|--|----------------|----------------|--|
| Bass | Monthly | 23 | 1.5 | 0.9 | 0.87 | 0.70 | 0 |
| Cape Woolamai | Monthly | 12 | | | 0.84 | 0.73 | 0 |
| Corinella | Monthly | 12 | | | 0.88 | 0.77 | 0 |
| Cowes | Monthly | 12 | | | 0.87 | 0.75 | 0 |
| Grantville | Monthly | 12 | | | 0.85 | 0.72 | 0 |
| Kilcunda | Monthly | 12 | | | 0.92 | 0.77 | 0 |
| Rhyll | Monthly | 12 | | | 0.87 | 0.76 | 0 |
| San Remo | Monthly | 12 | | | 0.84 | 0.73 | 0 |
| Ventnor | Monthly | 12 | | | 0.88 | 0.74 | 0 |

Table 5.4.1-2 Fluoride 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Target optimum operating fluoride concentration (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|-----------------------------|-----------|---------|--|--|----------------|----------------|--|
| Bass | Monthly | 2 | 1.5 | 0.9 | 0.51 | 0.50 | 0 |
| Cowes | Monthly | 1 | | | 0.59 | 0.59 | 0 |
| Kilcunda | Monthly | 1 | | | 0.59 | 0.59 | 0 |
| San Remo/ Phillip Island | Monthly | 4 | | | 0.57 | 0.55 | 0 |
| Water Line | Monthly | 2 | | | 0.59 | 0.53 | 0 |

5.4.2 Copper

Based on health considerations, the ADWG health-based guideline value is set at 2 mg/L, and at 1 mg/L for the aesthetic-based guideline. The copper concentration complied with both guideline values at all localities during the reporting period as per table 5.4.2-1 and 5.4.2-2 below:

Table 5.4.2-1 Copper 1 July 2017- 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|---------------|-----------|---------|--|----------------|----------------|--|
| Bass | Quarterly | 4 | 2 | 0.01 | 0.008 | 0 |
| Cape Woolamai | Quarterly | 4 | | 0.01 | 0.007 | 0 |
| Corinella | Quarterly | 4 | | 0.05 | 0.037 | 0 |
| Cowes | Quarterly | 4 | | 0.01 | 0.008 | 0 |
| Grantville | Quarterly | 4 | | 0.02 | 0.016 | 0 |
| Kilcunda | Quarterly | 4 | | 0.01 | 0.009 | 0 |
| Rhyll | Quarterly | 4 | | 0.04 | 0.014 | 0 |
| San Remo | Quarterly | 4 | | 0.04 | 0.017 | 0 |
| Ventnor | Quarterly | 4 | | 0.14 | 0.038 | 0 |

Table 5.4.2-2 Copper 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|-------------------------|-----------|---------|--|----------------|----------------|--|
| Bass | Quarterly | 1 | 2 | 0.03 | 0.03 | 0 |
| Cowes | Quarterly | 1 | | 0.003 | 0.003 | 0 |
| Kilcunda | Quarterly | 1 | | 0.01 | 0.01 | 0 |
| San Remo-Phillip Island | Quarterly | 4 | | 0.02 | 0.009 | 0 |
| Water Line | Quarterly | 4 | | 0.02 | 0.009 | 0 |

5.4.3 Lead

Based on health considerations, the ADWG guideline value is 0.01 mg/L. Lead concentrations complied with this guideline value at all localities during the reporting period as per table 5.4.3-1 and 5.4.3-2 below:

Table 5.4.3-1 Lead 1 July 2017- 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|---------------|-----------|---------|--|----------------|----------------|--|
| Bass | Quarterly | 4 | 0.01 | <0.001 | <0.001 | 0 |
| Cape Woolamai | Quarterly | 4 | | <0.001 | <0.001 | 0 |
| Corinella | Quarterly | 4 | | 0.001 | 0.001 | 0 |
| Cowes | Quarterly | 4 | | <0.001 | <0.001 | 0 |
| Grantville | Quarterly | 4 | | 0.004 | 0.002 | 0 |
| Kilcunda | Quarterly | 4 | | <0.001 | <0.001 | 0 |
| Rhyll | Quarterly | 4 | | <0.001 | <0.001 | 0 |
| San Remo | Quarterly | 4 | | 0.002 | 0.001 | 0 |
| Ventnor | Quarterly | 4 | | <0.001 | <0.001 | 0 |

¹ Results with a less than qualifier (<) are below the laboratory detection limit

Table 5.4.3-2 Lead 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|-----------------------------|-----------|---------|---|-------------------|-------------------|---|
| Bass | Quarterly | 1 | 0.01 | <0.001 | <0.001 | 0 |
| Cowes | Quarterly | 1 | | <0.001 | <0.001 | 0 |
| Kilcunda | Quarterly | 1 | | <0.001 | <0.001 | 0 |
| San Remo- Phillip Island | Quarterly | 4 | | <0.001 | <0.001 | 0 |
| Water Line | Quarterly | 2 | | <0.001 | <0.001 | 0 |

5.4.4 Zinc

Based on aesthetic considerations, the ADWG guideline value is set at 3 mg/L. The zinc concentration complied with this guideline value at all localities during the reporting period as per table 5.4.4-1 and 5.4.4-2 below:

Table 5.4.4-1 Zinc 1 July 2017- 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|---------------|-----------|---------|---|-------------------|-------------------|---|
| Bass | Quarterly | 4 | 3 | 0.008 | 0.004 | 0 |
| Cape Woolamai | Quarterly | 4 | | 0.01 | 0.005 | 0 |
| Corinella | Quarterly | 4 | | 0.02 | 0.008 | 0 |
| Cowes | Quarterly | 4 | | 0.01 | 0.008 | 0 |
| Grantville | Quarterly | 4 | | 0.04 | 0.018 | 0 |
| Kilcunda | Quarterly | 4 | | 0.006 | 0.003 | 0 |
| Rhyll | Quarterly | 4 | | 0.007 | 0.004 | 0 |
| San Remo | Quarterly | 4 | | 0.05 | 0.014 | 0 |
| Ventnor | Quarterly | 4 | | 0.09 | 0.025 | 0 |

Table 5.4.4-2 Zinc 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|-----------------------------|-----------|---------|---|-------------------|-------------------|---|
| Bass | Quarterly | 1 | 3 | 0.01 | 0.01 | 0 |
| Cowes | Quarterly | 1 | | 0.002 | 0.002 | 0 |
| Kilcunda | Quarterly | 1 | | 0.005 | 0.005 | 0 |
| San Remo- Phillip Island | Quarterly | 4 | | 0.01 | 0.005 | 0 |
| Water Line | Quarterly | 1 | | 0.01 | 0.01 | 0 |

5.4.5 Manganese

The ADWG health-based value is 0.5 mg/L, and 0.1 mg/L for aesthetic-based value. The manganese results met both ADWG values (for aesthetics and health) in all sampling localities during the reporting period as per table 5.4.5-1 and 5.4.5-2 below:

Table 5.4.5-1 Manganese 1 July 2017- 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|---------------|-----------|-----------------|---|-------------------|-------------------|---|
| Bass | Monthly | 33 | 0.5 | 0.03 | 0.005 | 0 |
| Cape Woolamai | Monthly | 33 | | 0.01 | 0.004 | 0 |
| Corinella | Monthly | 33 | | 0.13 | 0.007 | 0 |
| Cowes | Monthly | 33 | | 0.01 | 0.004 | 0 |
| Grantville | Monthly | 44 ² | | 0.07 | 0.006 | 0 |
| Kilcunda | Monthly | 33 | | 0.03 | 0.004 | 0 |
| Rhyll | Monthly | 33 | | 0.008 | 0.003 | 0 |
| San Remo | Monthly | 33 | | 0.009 | 0.003 | 0 |
| Ventnor | Monthly | 33 | | 0.02 | 0.003 | 0 |

²locality includes sampling from two treated storage tanks that supply Grantville and Corinella

Table 5.4.5-2 Manganese 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) | Number of samples where standard was not met (s. 18) |
|------------------------------|-----------|---------|---|-------------------|-------------------|---|
| Bass | Monthly | 2 | 0.5 | 0.002 | 0.001 | 0 |
| Cowes | Monthly | 3 | | 0.003 | 0.002 | 0 |
| Kilcunda | Monthly | 3 | | 0.002 | 0.001 | 0 |
| San Remo - Phillip Island | Monthly | 12 | | 0.003 | 0.002 | 0 |
| Water Line | Monthly | 7 | | 0.003 | 0.002 | 0 |

5.4.6 All other chemicals or monitored parameters

WPW also sample from water entering points and service basins that deliver water into each locality for health related aspects of drinking water. There are a number of sites that sample different parameters at varying frequencies. These are highlighted, along with compliance with ADWG, in table 5.4.6-1 below:

Table 5.4.6-1 other health related parameters sampled at water entering points and service basins

| Parameter | Frequency | Samples | Drinking water quality standard (mg/L) | Number of samples where standard was not met (s. 18) |
|----------------------|-------------|---------|--|--|
| Chromium (as Cr(VI)) | Quarterly | 40 | <0.05 | 0 |
| Cyanide | Annually | 10 | <0.08 | 0 |
| Nitrate | Fortnightly | 216 | <50 | 0 |
| Nitrite | Fortnightly | 216 | <3 | 0 |
| Sulphate | Annually | 3 | <250 | 0 |

5.4.7 Raw water monitoring

As described in section 2.1, the raw water quality in Candowie Reservoir is impacted by farming throughout the open catchment. For this reason WPW monitors a number of parameters in the raw water storage to detect changes in water quality, allowing for proactive management of water treatment processes. Parameters, sampling frequency and location are tabulated below.

WPW reviewed its water sampling program in line with regulation 13 of SDWR 2015. Regulation 13 requires samples of drinking water to be collected at a frequency detailed in the WQRMP.

Table 5.4.7-1 raw water monitoring

| Location | Frequency | Parameter |
|---|--|---|
| Raw water offtake | Daily | Fluoride, turbidity, pH, iron and manganese |
| | Weekly | <i>E. coli</i> and coliforms |
| | Fortnightly (or increased as required) | Methyl Iso-Borneol (MIB) and geosmin |
| | Monthly | Alkalinity dissolved organic carbon electrical conductivity @25°C and electrical conductivity |
| | Quarterly | Herbicides and pesticides, cryptosporidium and giardia |
| | Annually | Metals (silver iodide, tin, barium, boron, mercury, molybdenum, selenium and beryllium) and radiation |
| Profile sampling at surface, 1, 3, 7 and 9 meter depths | Fortnightly (or increased as required) | Blue green algae, nitrate, nitrite, ammonia, phosphorus, silica, iron and manganese |
| Surface and every meter interval (up to 10m) | Fortnightly | Temperature, dissolved oxygen, pH and |

5.4.8 Analysis of results

The quality of drinking water supplied to our customers was 100% compliant with requirements detailed in, SDWR 2015 and WPW'S WQRMP in 2017-18.

WPW has also reached 100% compliance with these requirements for the two previous reporting periods, 2015-16 and 2016-17 respectively. For more information on the previous reporting periods please visit our publications page on our website:

<http://www.westernportwater.com.au/learning-centre/resources-support/forms-publications/>

5.4.9 Water quality improvements in 2017-18

Water quality improvements during 2017-18 were:

- Construction of Ultraviolet Disinfection was completed at IBWPP in March 2018. This provides our treatment process with a multiple barrier approach for pathogen removal.
- Filter to waste was commissioned at IBWPP in May 2018. This addition provides further control to filter operation and greatly reduces the risk of out of specification water being delivered to customers.
- Turbidity filter performance met the Health Based Target guideline of <0.2 NTU 95% of the time and not >0.5 NTU for 15 consecutive minutes throughout 2017-18.
- Mechanical mixers installed in clear water storages to aid in mixing during disinfection and to reduce short circuiting and water age within storages, improving the aesthetics of the water.
- Annual air scouring of water mains continued as an annual routine program.
- Continuous monitoring (CCTV) installed at critical assets improving security and asset protection.
- Filter media was added to two filters. The other filter was topped up in 2016-17.
- Commencement of a backflow prevention project. This project will provide protection of the distribution system against contamination from private supplies.
- Adoption of the 5C's principle to ensure best practice is followed during repairs in the distribution system.

5.5 Aesthetics

The SDWR 2015 refers to aesthetic water quality and states the annual report must include the steps taken by a water supplier to manage aesthetic characteristics of drinking water supplied. Along with verification monitoring of colour and pH, WPW undertake jar testing for optimum coagulant dosing. Other steps taken to manage aesthetics are reactive maintenance programs: annual air scouring of the distribution pipe network and reactive flushing. The ADWG set the aesthetic based guideline values for aluminium, true colour, iron and pH. Those parameters sampled throughout the distribution system, indicating compliance, are presented in tables below.

5.5.1 Aluminium (acid-soluble)

Based on aesthetic considerations, the ADWG guideline value is 0.2 mg/L. The aluminium concentration complied with this guideline value at all localities during the reporting period as per table 5.5.1-1 and 5.5.1-2 below:

Table 5.5.1-1 Aluminium 1 July 2017 – 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) |
|---------------|-----------|---------|--|----------------|----------------|
| Bass | Quarterly | 3 | 0.2 | 0.01 | 0.01 |
| Cape Woolamai | Quarterly | 3 | | 0.01 | 0.01 |
| Corinella | Quarterly | 3 | | 0.01 | 0.01 |
| Cowes | Quarterly | 3 | | 0.01 | 0.01 |
| Grantville | Quarterly | 3 | | 0.03 | 0.02 |
| Kilcunda | Quarterly | 3 | | 0.02 | 0.01 |
| Rhyll | Quarterly | 3 | | 0.02 | 0.01 |
| San Remo | Quarterly | 3 | | 0.01 | 0.01 |
| Ventnor | Quarterly | 3 | | 0.01 | 0.01 |

Table 5.5.1-2 Aluminium 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) |
|-------------------------|-----------|---------|--|----------------|----------------|
| Bass | Quarterly | 1 | 0.2 | 0.01 | 0.01 |
| Cowes | Quarterly | 1 | | 0.02 | 0.02 |
| Kilcunda | Quarterly | 1 | | 0.02 | 0.02 |
| San Remo-Phillip Island | Quarterly | 4 | | 0.01 | 0.01 |
| Water Line | Quarterly | 2 | | <0.01 | <0.01 |

5.5.2 True colour

Sampling for true colour was undertaken at water entering points into the distribution system - not at customer taps. The table below presents the data from a locality perspective rather than for individual water sampling points. The ADWG value is set at 15 HU. True colour results met ADWG in all sampling localities during the reporting period as per table 5.5.2-1 and 5.5.2-2 below:

Table 5.5.2-1 True colour 1 July 2017 – 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (HU) | Maximum (mg/L) | Average (mg/L) |
|---------------|-----------|----------------|--------------------------------------|----------------|----------------|
| Bass | Quarterly | 3 | 15 | 2 | 2 |
| Cape Woolamai | Quarterly | 3 | | 2 | 2 |
| Corinella | Quarterly | 3 | | 2 | 2 |
| Cowes | Quarterly | 3 | | 2 | 2 |
| Grantville | Quarterly | 6 ¹ | | 2 | 2 |
| Kilcunda | Quarterly | 3 | | 2 | 2 |
| Rhyll | Quarterly | 3 | | 2 | 2 |
| San Remo | Quarterly | 3 | | 2 | 2 |
| Ventnor | Quarterly | 3 | | 2 | 2 |

¹locality includes sampling from two treated storage tanks that supply Grantville and Corinella

Table 5.5.2-2 True colour 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (HU) | Maximum (mg/L) | Average (mg/L) |
|-------------------------|-----------|----------------|--------------------------------------|----------------|----------------|
| Bass | Quarterly | 1 | 15 | 2 | 2 |
| Cowes | Quarterly | 1 | | 2 | 2 |
| Kilcunda | Quarterly | 1 | | 2 | 2 |
| San Remo-Phillip Island | Quarterly | 4 | | 2 | 2 |
| Water Line | Quarterly | 3 ¹ | | 2 | 2 |

¹locality includes sampling from two treated storage tanks that supply Grantville and Corinella



5.5.3 Iron

Based on aesthetic considerations, the ADWG guideline value is 0.3 mg/L. All localities were compliant with the ADWG in the 2017-18 reporting period as highlighted in table 5.5.3-1 and 5.5.3-2 below:

Table 5.5.3-1 Iron 1 July 2017 – 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) |
|---------------|-----------|---------|--|----------------|----------------|
| Bass | Monthly | 11 | 0.3 | 0.03 | 0.01 |
| Cape Woolamai | Monthly | 11 | | 0.04 | 0.02 |
| Corinella | Monthly | 11 | | 0.08 | 0.02 |
| Cowes | Monthly | 11 | | 0.07 | 0.02 |
| Grantville | Monthly | 11 | | 0.03 | 0.02 |
| Kilcunda | Monthly | 12 | | 0.02 | 0.01 |
| Rhyll | Monthly | 11 | | 0.03 | 0.02 |
| San Remo | Monthly | 11 | | 0.08 | 0.03 |
| Ventnor | Monthly | 11 | | 0.07 | 0.03 |

Table 5.5.3-2 Iron 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard (mg/L) | Maximum (mg/L) | Average (mg/L) |
|-------------------------|-----------|---------|--|----------------|----------------|
| Bass | Monthly | 1 | 0.3 | <0.01 | <0.01 |
| Cowes | Monthly | 1 | | 0.03 | 0.03 |
| Kilcunda | Monthly | 1 | | 0.01 | 0.01 |
| San Remo-Phillip Island | Monthly | 4 | | 0.04 | 0.02 |
| Water Line | Monthly | 2 | | 0.02 | 0.01 |

5.5.4 pH

The ADWG aesthetic value for pH is >6.5 and <8.5. All localities were compliant with the ADWG in the 2017-18 reporting period as highlighted in table 5.5.4-1 and 5.5.4-2 below:

Table 5.5.4-1 pH 1 July 2017 – 29 May 2018

| Locality | Frequency | Samples | Drinking water quality standard | Minimum | Maximum |
|---------------|-------------|---------|---------------------------------|---------|---------|
| Bass | Fortnightly | 22 | 6.5-8.5 | 7.1 | 7.5 |
| Cape Woolamai | Fortnightly | 22 | | 7.2 | 7.7 |
| Corinella | Fortnightly | 22 | | 7.3 | 7.5 |
| Cowes | Fortnightly | 22 | | 7.4 | 8.2 |
| Grantville | Fortnightly | 22 | | 7.2 | 7.7 |
| Kilcunda | Fortnightly | 22 | | 7.3 | 7.8 |
| Rhyll | Fortnightly | 22 | | 7.4 | 7.8 |
| San Remo | Fortnightly | 22 | | 7.2 | 7.7 |
| Ventnor | Fortnightly | 22 | | 7.4 | 8.3 |

Table 5.5.4-2 pH 30 May 2018 – 30 June 2018

| Locality | Frequency | Samples | Drinking water quality standard | Minimum | Maximum |
|-------------------------|-------------|---------|---------------------------------|---------|---------|
| Bass | Fortnightly | 1 | 6.5-8.5 | 7.2 | 7.2 |
| Cowes | Fortnightly | 2 | | 7.6 | 7.8 |
| Kilcunda | Fortnightly | 2 | | 7.3 | 7.3 |
| San Remo-Phillip Island | Fortnightly | 8 | | 7.3 | 8 |
| Water Line | Fortnightly | 4 | | 7.2 | 7.5 |

6. Complaints relating to water quality

6.1 Summary of complaints

The number of customer complaints to WPW regarding drinking water totalled 30 for 2017/18. This was an increase of 10 from 2016/17. Table 6.1-1 details the type of customer complaints. Table 6.1-2 details water quality complaints by sampling locality.

Table 6.1-1 Customer^ complaints relating to water quality

| Type of complaint | Number of complaints | | | Comparison with previous reporting periods | Comments |
|-------------------|----------------------|-----------|-----------|---|---|
| | 2017-18 | 2016-17 | 2015-16 | | |
| Discoloured water | 15 | 10 | 13 | Slight increase from previous year. | Increase from previous year can be attributed to planned air scouring and bursts and leaks repairs. |
| Taste/odour | 8 | 2 | 18 | Increase from previous year but a reduction from prior years. | Ongoing water quality improvements as discussed in 5.4.9. |
| Other* | 7 | 8 | 9 | No significant change | Nil |
| Total | 30 | 20 | 40 | 33% increase from 2016-17 | Although there was an increase in customer complaints from 2016-17 numbers were similar to previous years. |

Table 6.1-2 Complaints by water sampling locality

| Locality | Type of complaint | | | Total |
|----------------------|-------------------|-------------|--------|-------|
| | Discoloured water | Taste/odour | Other* | |
| Bass | 1 | 0 | 0 | 1 |
| Cape Woolamai | 4 | 2 | 0 | 6 |
| Corinella | 4 | 4 | 2 | 10 |
| Cowes | 2 | 2 | 2 | 6 |
| Grantville | 0 | 0 | 0 | 0 |
| Kilcunda | 2 | 0 | 0 | 2 |
| Rhyll | 1 | 0 | 1 | 2 |
| San Remo | 0 | 0 | 0 | 0 |
| Ventnor | 1 | 0 | 0 | 1 |
| Unknown ¹ | 0 | 0 | 2 | 2 |

[^]for the purposes of this section, the term 'customer' has the same meaning as that used by the Essential Services Commission, that is, a customer = a connection

^{*}this category includes any contact related to alleged illness

¹Complaints that were received where an address was not provided, unable to allocate to a sampling locality.

50% of complaints were for discoloured colour, 27% taste/odour and 23% for other.

The majority of complaints were due to reactive maintenance works where there was a burst or leak of the distribution network resulting in discoloured water. Flushing after works corrected any complaint received. There were no media releases or public announcements associated with water quality complaint.

Total customer complaints increased from 20 in 2016-17 to 30 in 2017-18. The 33% increase was due to ongoing preventative maintenance works. The routine air scouring program and reactive maintenance from bursts and leaks can be attributed to the discoloured water complaints.

6.2 Response to complaints

WPW is committed to providing its customers with ongoing quality water and services. Our customer service division manages customer complaints and each complaint is lodged using an entry form in WPW customer request management (CRM) system. Depending on the nature of the complaint, the details are electronically forwarded to the Water Quality and Sustainability Officer for water quality complaints; the Maintenance group for bursts and leaks.

After a complaint is lodged, depending on the nature of the complaint, one or a combination of the following actions may be performed:

- Proceed with remedial action such as water sample testing, mains flushing and sometimes water sampling testing after flushing;
- Contact the customer who lodged the complaint to determine the seriousness of the issue;



- Discuss with the complainant the possible causes of the poor water quality i.e. temporary changes to normal operation or high manganese and/or iron in raw water;
- Explain to the complainant the multiple barriers and rigorous sampling and testing regime employed to provide a safe and aesthetically acceptable water; and
- Give feedback to customer in terms of water quality information and links to further information regarding regulatory obligations.

7. Findings of the most recent risk management plan audit

Written notice was provided by DHHS in October 2017 advising that an audit of Risk Management Plans (RMP) must occur by 31 May 2018. Westernport Waters audit took place on 17-18 May 2018. Westernport Water was found to be compliant with the Section 7(i) of the SDWA.

Risk management plan audit certificate

Safe Drinking Water Regulations 2015 - Regulation 10

Certificate Number:

Audit period:

To:

Australian Business Number (ABN):

I, , after conducting a risk management plan audit of
 the water supplied by am of the opinion that -
 has complied with the obligations
 imposed by section 7(1) of the *Safe Drinking Water Act 2003* during the audit period.

Signature of approved auditor: Date:

Department of Health & Human Services



Figure 7-1 Risk management plan audit certificate

Opportunities for improvement (OFI's) identified during the audit are listed in table 6.2-1 including the status of the OFI and expected completion date.

Table 7-1 OFI's identified during audit

| OFI | Status | Completion Date |
|---|--|-----------------|
| Over the longer term, consider committing to installing two or more conventional fixed roof water tanks in place of the single San Remo Basin with its floating cover. | To be considered in Year 3 of Pricing Submission | 2020-21 |
| Complete the roll-out of monochloramine and free ammonia analysers to cover the remaining Grantville Tank. To provide full coverage for this best practice monitoring program to help inform the challenging task of managing chloramine residuals. | Investigation underway to determine if OFI to be implemented | 2018-19 |
| In continuing with its backflow prevention program, WPW is encouraged to consider the ongoing workload that this creates and resource that workload. Any backflow prevention role could be linked to recycled water and trade waste management roles. The role could link to the trend for more proactive involvement by water utilities in oversighting plumbing to help fill a regulatory weakness. | Project underway | 2019-20 |
| WPW is encouraged to look at better formalising an obligation on its materials suppliers to only supply pipes, parts, fittings, coatings, etc., that are fit-for-purpose as materials in contact with drinking water, where relevant. | Investigation underway to determine most suitable method. | 2018-19 |
| WPW is encouraged to progress with its plans to create a suitably sized and outfitted storage depot that permits chemicals, parts, and fittings to be stored undercover, off the ground, in clean, sanitary conditions, out of sunlight and at suitable temperatures. | Project underway | 2020-21 |

8. Undertakings under section 30 of the Act

WPW currently has no section 30 undertakings.

9. Regulated Water

No regulated water was supplied during the reporting period.



10. Exemption under section 20 of the Act

WPW has no exemptions under section 20.



11. Glossary of Terms

WPW must make this document and all water quality monitoring information available to public disclosure within 7 days of the request. For information pertaining to water quality in WPW's region please contact the Water Quality and Sustainability Officer via:

Email: sosullivan@westernportwater.com.au,

Website <http://www.westernportwater.com.au/water-quality/>

Phone (03) 5956 4161.

| Term | Meaning |
|---------------|---|
| ADWG | Australian Drinking Water Guidelines, 2011 prepared by the National Health and Medical Research Council |
| CRM | Customer Request Management system |
| DAFF | Dissolved Air Floatation and Filtration |
| DHHS | Department of Health and Human Services |
| <i>E.coli</i> | <i>Escherichia coli</i> |
| GMU | Groundwater Management Unit |
| IBWPP | Ian Bartlett Water Purification Plant |
| mg/L | Milligram per litre |
| NTU | Nephelometric Turbidity Units |
| PAC | Powdered Activated Carbon |
| SCADA | Supervisory Control and Data Acquisition |
| SDWA | <i>Safe Drinking Water Act, 2003 (Victoria)</i> |
| SDWR | Safe Drinking Water Regulations, 2015 |
| THM | Trihalomethanes |
| UCL | Upper Confidence Limit |
| WPW | Westernport Water |
| RMP | Risk Management Plan |